



Suite 201, 531 Kingsway  
Miranda NSW 2228  
t: (02) 8544 1683  
w: www.greenview.net.au  
Greenview Consulting Pty Ltd  
A.B.N 32 600 067 338

## HYDRAULIC & FIRE DESIGN INTENT STATEMENT

**PROJECT:** 56-58 Beane Street, Gosford

**DATE:** 02.12.2019

**CLIENT:** Mono Constructions

**REFERENCE:** 190708

**ADDRESS:** 56-58 Beane Street, Gosford NSW 2250

We confirm that the above design will be in accordance with normal engineering practice and meet the requirements of the National Construction Code, relevant Australian Standards and relevant conditions of the Development Consent. In particular, the design will be in accordance with the following:

Reference	Title
AS/NZS 3500:2018	Plumbing and Drainage Set
AS 2419.1:2005	Fire Hydrant Installations Part 1: System Design, Installation And Commissioning
AS 2441:2005	Installation of Fire Hose Reels
AS/NZS 5601.1:2013	Gas Installations Part 1: General Installations
Technical Specification FPAA101H*	Automatic Fire Spinkler System Design and Installation – Hydrant Water Supply
NCC - Section E	Services and Equipment Parts E1.3, E1.4, Part E1.5, Specification E1.5 and Specification E1.5a
NCC - Section J	Energy Efficiency Part J7.2

\*Greenview Consulting understands the proposed building has been deemed to have an effective height of less than 25m and a rise in storeys of four or more.

We confirm that the computations for the design have been carried out by a practicing qualified Engineer.

Yours faithfully,

For & on behalf of Greenview Consulting.  
Craig Welsby  
Senior Hydraulic & Fire Engineer